



LEEDS
BECKETT
UNIVERSITY

Citation:

Butler, MB and Sloof, D and Peters, C and Conway Morris, A and Gouliouris, T and Thaxter, R and Keevil, VL and Beggs, CB (2023) Impact of supplementary air filtration on aerosols and particulate matter in a UK hospital ward: a case study. *Journal of Hospital Infection*, 135. pp. 81-89. ISSN 0195-6701 DOI: <https://doi.org/10.1016/j.jhin.2023.02.006>

Link to Leeds Beckett Repository record:

<https://eprints.leedsbeckett.ac.uk/id/eprint/9402/>

Document Version:

Article (Published Version)

Creative Commons: Attribution 4.0

(c) 2023 The Author(s).

The aim of the Leeds Beckett Repository is to provide open access to our research, as required by funder policies and permitted by publishers and copyright law.

The Leeds Beckett repository holds a wide range of publications, each of which has been checked for copyright and the relevant embargo period has been applied by the Research Services team.

We operate on a standard take-down policy. If you are the author or publisher of an output and you would like it removed from the repository, please [contact us](#) and we will investigate on a case-by-case basis.

Each thesis in the repository has been cleared where necessary by the author for third party copyright. If you would like a thesis to be removed from the repository or believe there is an issue with copyright, please contact us on openaccess@leedsbeckett.ac.uk and we will investigate on a case-by-case basis.



ELSEVIER

Available online at www.sciencedirect.com

Journal of Hospital Infection

journal homepage: www.elsevier.com/locate/jhin

Impact of supplementary air filtration on aerosols and particulate matter in a UK hospital ward: a case study

M.J. Butler^a, D. Sloof^b, C. Peters^c, A. Conway Morris^{d,e,f}, T. Gouliouris^f,
R. Thaxter^g, V.L. Keevil^{a,f}, C.B. Beggs^{a,h,*}

^a Department of Medicine for the Elderly, Cambridge University Hospitals, Cambridge, UK

^b AirPurity UK, Ltd, Cambridge, UK

^c Department of Microbiology, NHS Greater Glasgow and Clyde, Glasgow, UK

^d John V Farman Intensive Care Unit, Cambridge University Hospitals, Cambridge, UK

^e Division of Immunology, Department of Pathology, University of Cambridge, Cambridge, UK

^f Department of Medicine, University of Cambridge, Cambridge, UK

^g Infection Prevention and Control, Cambridge University Hospitals, Cambridge, UK

^h Carnegie School of Sport, Leeds Beckett University, Leeds, UK

ARTICLE INFO

Article history:

Received 14 December 2022

Accepted 16 February 2023

Available online 24 February 2023

Keywords:

HEPA filters

Air filtration

COVID-19

SARS-CoV-2

Airborne

Medicine for older people



SUMMARY

Background: Aerosol spread of severe acute respiratory syndrome coronavirus-2 (SARS-CoV-2) is a major problem in hospitals, leading to an increase in supplementary high-efficiency particulate air filtration aimed at reducing nosocomial transmission. This article reports a natural experiment that occurred when an air cleaning unit (ACU) on a medicine for older people ward was switched off accidentally while being commissioned.

Aim: To assess aerosol transport within the ward and determine whether the ACU reduced airborne particulate matter (PM) levels.

Methods: An ACU was placed in a ward comprising two six-bedded bays plus three single-bed isolation rooms which had previously experienced several outbreaks of coronavirus disease 2019. During commissioning, real-time measurements of key indoor air quality parameters (PM_{1–10}, CO₂, temperature and humidity) were collected from multiple sensors over 2 days. During this period, the ACU was switched off accidentally for approximately 7 h, allowing the impact of the intervention on PM to be assessed.

Findings: The ACU reduced the PM counts considerably (e.g. PM₁ 65.5–78.2%) throughout the ward ($P < 0.001$ all sizes), with positive correlation found for all PM fractions and CO₂ ($r = 0.343$ – 0.817 ; all $P < 0.001$). PM counts rose/fell simultaneously when the ACU was off, with correlation of PM signals from multiple locations (e.g. $r = 0.343$ – 0.868 ; all $P < 0.001$) for particulates $< 1 \mu\text{m}$.

Conclusion: Aerosols migrated rapidly between the various ward subcompartments, suggesting that social distancing alone cannot prevent nosocomial transmission of SARS-CoV-2 as this fails to mitigate longer-range (> 2 m) transmission. The ACU reduced PM levels considerably throughout the ward space, indicating its potential as an effective intervention to reduce the risk posed by infectious airborne particles.

© 2023 The Author(s). Published by Elsevier Ltd on behalf of The Healthcare Infection Society. This is an open access article under the CC BY license (<http://creativecommons.org/licenses/by/4.0/>).

* Corresponding author. Address: Carnegie School of Sport, Leeds Beckett University, Headingley Campus, Church Wood Avenue, Leeds LS6 3QS, UK
E-mail address: c.beggs@leedsbeckett.ac.uk (C.B. Beggs).

Introduction

The coronavirus disease 2019 (COVID-19) pandemic has rapidly advanced understanding of how infections can spread within buildings. It is now known that small aerosol particles are dominant in the transmission of severe acute respiratory syndrome coronavirus-2 (SARS-CoV-2) [1–6] and, likely, many other respiratory viruses [7,8]. Aerosols are formed when exhaled respiratory particles <100 µm in diameter evaporate rapidly to approximately 20–34% of their original size [9–11]. These remain suspended in the air for many minutes [12] and can be readily inhaled, with those in the range 2.5–20 µm accounting for 90% of viral transmission at the nasopharynx [11]. As such, transmission of SARS-CoV-2 is thought to occur primarily when infectious aerosol particles of this size come into contact with angiotensin-converting enzyme 2 (ACE2) receptors in the nasopharynx [13]. In addition, ACE2 receptors further down the respiratory tree, including on the alveolar epithelial cells, are a likely portal of entry. Inhalation of smaller particles <5 µm down to the alveoli may therefore also contribute to acquisition of infection, and possibly heighten the severity of disease [14,15].

Infectious respiratory aerosols can be liberated in large quantities when talking, singing or simply breathing [16–18], and may build up to high concentrations in room air if the space is not ventilated adequately [12]. Consequently, poorly ventilated spaces containing infectious individuals, such as hospital wards, pose a considerable threat to patients and healthcare workers (HCWs) alike, with numerous nosocomial COVID-19 outbreaks reported [19–27]. The problem can be particularly acute on wards containing older and/or immunocompromised patients who are vulnerable to severe disease following viral infection [28]. Furthermore, in open-plan wards with multi-bedded bays, pressure gradients may exist due to room mechanical ventilation or wind pressure, causing respiratory aerosol particles to migrate considerable distances. As such, vulnerable patients some distance (>2 m) from an infector may become exposed [29]. Realization of this issue has promoted interest in non-pharmaceutical interventions, such as supplementary room air filtration [30], air disinfection [31,32], and the use of carbon dioxide (CO₂) monitoring to optimize ventilation [33,34].

This article reports the results of a natural experiment that occurred on a medicine for older people ward at an NHS university hospital in the UK, when a room air cleaning unit (ACU) containing high-efficiency particulate air (HEPA) filters and ultraviolet-C (UV-C) air disinfection lamps was being commissioned. It was possible to test the hypothesis that particulate matter (PM) levels in the air throughout the space were higher when the ACU was not in operation compared with a matched period on the following day when the ACU was switched on. The authors were also able to gain insights into the transport of aerosols around the ward by correlating the various PM signals from the respective sensors.

Methods

Ward layout and ventilation

The study involved half a ward on the sixth floor of the hospital, which comprised three side rooms, each with a door,

and two six-bedded bays open to a central corridor (Figure 1). The ward was ventilated by a central ducted mechanical ventilation system and openable aluminium sash windows, with the bed bays and side rooms positively pressurized with respect to the central corridor. As this study was retrospective, taking advantage of a natural experiment, the 'open/closed' status of the various windows and doors on the ward was not recorded. Anecdotally, both doors and windows were frequently opened and closed depending on the clinical, operational and comfort requirements of the patients and HCWs. Historical measurements taken by the hospital estates department in 2020 indicated that the ward ventilation rates ranged from 1.7 to 5.8 (median 4.0) air changes per hour. The ACU was sited in an open communal space, which was the most densely populated part of the ward, with HCWs tending to congregate there prior to individual patient care activities.

Air cleaning unit

A single ACU (AeroTitan3000; AirPurity UK Ltd, Cambridge, UK) was sited opposite the two six-bedded patient bays (Figure 1, Figure S1 and Table S1, see online supplementary material). The ACU was a hybrid system that combined HEPA filters and UV-C lamps (at 254 nm), and had a clean air delivery rate (CADR) of 2550–3000 m³/h (Table S1, see online supplementary material). The unit produced a laminar flow that manipulated the air currents in the ward space at multiple heights at a distance >10 m, promoting greater mixing and enhancing the dilution effect.

The natural experiment occurred on 3rd and 4th August 2021. The ACU was switched off accidentally early in the morning of the first day; a mistake rectified by the afternoon of the same day.

Sensors

Seven sensors (AeroSentinel.v1; AirPurity UK Ltd) recorded indoor air quality data with the following accuracies: PM fraction <1 µm diameter (PM1) and PM fraction between 1 and 2.5 µm diameter (PM2.5) (±10 µg/m³); PM fraction between 2.5 and 4 µm diameter (PM4) and PM fraction between 4 and 10 µm diameter (PM10) (±25 µg/m³); CO₂ (±30 ppm); temperature (±0.4 °C); and relative humidity (±3%) (Table S2, see online supplementary material). Sensor A was situated close to the ACU at a height of 2 m, with the remaining sensors placed at heights ranging from 1.5 to 1.7 m depending on available electrical outlets (Figure 1).

Data

Data from the various sensors was sampled every 1 min, giving a total of 2782 data points per sensor over the 2-day period. In total, 7.6% of the data were missing, and this was imputed as the mean value of the adjacent data points.

Change point analysis and validation

As contemporaneous records were not kept regarding the precise points in time when the ACU was switched off and on, to avoid the use of any a-priori assumptions, change point (CP) analysis [35,36] was employed using pruned exact linear time methodology [37]. Sensor A was selected for this analysis as it




Figure 1. Layout of the medicine for older people ward showing the positions of the air cleaning unit (ACU) and sensors (green diamonds).

was best placed to monitor both occupancy levels and the ACU. CPs were identified by visual inspection, and tested statistically using the Chow test, with $P < 0.05$ deemed to indicate significance.

Primary statistical analysis

The hypothesis tested was that the respective PM levels were higher when the ACU was not in operation on the first day compared with a matched period on the second day when the ACU was in operation. This was tested using an unpaired Mann–Whitney test in R (R Core Team, 2021; <https://www.R-project.org/>). The observed effect size was evaluated using Cliff's delta statistic, with the magnitude assessed using the thresholds provided by Romano *et al.* [38] (i.e. $|\delta| < 0.147$ negligible; $0.147 \leq |\delta| < 0.33$ small; $0.33 \leq |\delta| < 0.474$ medium; $0.474 \leq |\delta|$ large).

To assess the relationships between the signals from the individual sensors, Pearson correlation r values were

computed, together with their statistical significance. This was done for each individual sensor using data for the entire study period. In addition, the extent to which airborne PM may be migrating around the ward was assessed by analysing the between-sensor correlations for each air quality metric, using only the data collected when the ACU was off. For all tests, $P < 0.05$ was deemed to indicate significance.

Results

Change point analysis results

Five CPs were identified, as shown in Figure 2. Of these, Table I shows that CP1 and CP2 (representing when the ACU was accidentally switched off and turned back on again) closely coincided with the approximate time-stamps that were recovered from the ACU memory card in December 2021. CP4 occurred when the power/speed of the ACU was increased. The

reasons for the changes observed at CP3 and CP5 are unclear. CP3 might reflect the downturn in activity that generally occurred on the ward after the evening meal.

Descriptive time series results

Figure 3 shows the collated PM1 time series data over 2 days from each sensor (A–G). Similar patterns for all other PM fractions were also observed (Figures S2–4, see online supplementary material). All sensors demonstrated large increases in particulates of all sizes throughout the ward when the ACU was off. Noticeably, all sensors around the ward detected similar signals with respect to PM and CO₂ levels at similar times (Figures 3 and 4, and Figures S2–4, see online supplementary material).

Statistical analysis results

The visual observations were confirmed by the means and standard deviations of the sensor signals for the periods before, between and after the identified CPs. These are shown in Table S3 (see online supplementary material) and, for all the sensors, the observed signal readings were much higher between CP1 and CP2 when the ACU was off compared with all other periods. In particular, Table II shows the respective signal levels were higher when the ACU was not in operation on the first day compared with a matched period on the second day when the ACU was in operation ($P < 0.001$ for all sensors). With respect to this, a large effect size was observed for PM1, PM2.5, CO₂ and vapour pressure levels. In comparison, the effect size for the PM4 and PM10 signals was much smaller, although still significant.

Within- and between-sensor correlations

Within all sensors, strong positive correlations were observed between most of the signals (Figure S5 and Table S4, see online supplementary material). PM signals were strongly correlated with each other ($r = 0.718–0.996$), and CO₂ and

vapour pressure were positively correlated with the PM signals and each other, although not as strongly ($r = 0.387–0.732$).

When the ACU was switched off, aerosol particle counts tended to rise and fall simultaneously throughout the ward space. Strong correlations were observed for all metrics between all the sensors ($r = 0.723–0.868$), except for Sensor F ($r = 0.343–0.552$) (Table S5, see online supplementary material). Sensor F was distal to the ACU and located in a narrow corridor space with a less predictable air flow.

Discussion

This natural experiment is the first of its kind to evaluate the sequential transport of airborne PM around a medical ward, and to assess the impact of an ACU on this. This study showed that particles up to 10 μm (beyond the 5 μm aerosol/droplet cut-off used previously) travelled considerable distances around the ward (beyond 2 m), and that the ACU reduced PM levels of all sizes throughout the space, not just in close proximity to the device. While the authors did not distinguish between bioaerosols and inert aerosols, it is likely that the monitored PM behaviour was indicative of any bioaerosols present in the ward air because viral particles tend to occur mainly in smaller respiratory aerosols $< 5 \mu\text{m}$ [39–41]. As such, these findings shed new light on the transport of aerosols around hospital wards, and increase understanding of airborne transmission of viruses such as SARS-CoV-2 in real-life clinical settings.

The considerable movement of particles of all sizes around the ward was evidenced by the simultaneous rise and fall in the PM counts measured by the multiple sensors when the ACU was switched off accidentally. This illustrates the potential for inhalational exposure to infectious agents at some distance from an infected individual. Although the authors did not measure bioaerosols or the presence of infectious agents directly, previous studies have shown that respiratory viruses are most likely to be recovered from particles $< 5 \mu\text{m}$ [39–42], suggesting that they are contained in exhaled bioaerosols that have undergone rapid evaporation [9]. When speaking, 80–94% of the respiratory particles produced are $\leq 100 \mu\text{m}$ [43], and




Figure 2. Particulate matter (PM) fraction $< 1 \mu\text{m}$ diameter (PM1) signal from Sensor A (black) with the interrupted mean signal (blue) for the sections between the major change points (CP). Major CPs were identified at epochs 497, 935, 1092, 1982 and 2389. Epochs are in min.

Table 1

Occurrence of major change points (CP) in particulate matter fraction $<1 \mu\text{m}$ diameter (PM1) signal for Sensor A, together with time-stamp data recovered from the air cleaning unit (ACU)

CP	CP epoch	CP time and date	Significance (P-value)	Time-stamp recovered from ACU	Reason for change
CP1	497	08:17 (3 rd Aug)	<0.001	08:16 (3 rd Aug)	ACU switched off
CP2	935	15:35 (3 rd Aug)	<0.001	15:34 (3 rd Aug)	ACU switched on
CP3	1092	18:12 (3 rd Aug)	<0.001	N.A.	Not known
CP4	1982	09:02 (4 th Aug)	<0.001	09:05 (4 th Aug)	ACU speed setting adjusted
CP5	2389	15:49 (4 th Aug)	<0.001	N.A.	Not known

these quickly reduce to 30% of their original diameter through evaporation under normal room conditions [44]. This means that the vast majority of exhaled particles become aerosolized, with only particles $>100 \mu\text{m}$ behaving ballistically [45,46]. Given that median (range) aerosol particle emission rates of 135 particles/s (range 85–691) for breathing, 270 particles/s (range 120–1380) for normal talking and 570 particles/s (range 180–1760) for loud talking have been recorded [18], this suggests that, on a typical medical ward, many thousands of respiratory aerosols are likely to be liberated in the size range represented by the PM signals [43]. These are then likely to remain airborne and potentially migrate around the ward, as observed in this study. Thus, these findings may help explain why nosocomial outbreaks of COVID-19, including superspreading events involving multiple subcompartments, have occurred despite the application of social distancing measures between patients [21].

It is likely that the observed PM migration around the ward was assisted by the turbulent wakes formed as HCWs move, which can transport airborne particulates considerable

distances [12,47]. The extent of this particle transport was somewhat unexpected because the ward ventilation system was designed to promote flow in one direction towards the corridor, which should have inhibited the movement of PM between the various bays. At present, the movement of individuals and equipment remains a significant blind spot in traditional computational fluid dynamics modelling, which usually models static scenarios. Thus, a strength of the current study is that particle movement was tracked in a real-world setting whilst ward business continued as usual. Collectively, this suggests that respiratory aerosols, many of which are $<5 \mu\text{m}$ diameter, can be widely disseminated around wards, and that social distancing measures alone are unlikely to prevent the transmission of infection [29].

Interestingly, when the ACU was off, PM levels of all sizes were positively correlated with indoor CO_2 levels. This suggests that human activity such as movement, bed making, washing, etc. is key to generating particulates [48,49]. This is of particular interest given that CO_2 monitoring has been used to infer airborne infection risk in enclosed/shared spaces [50].




Figure 3. Collated smoothed particulate matter (PM) fraction $<1 \mu\text{m}$ diameter (PM1) signals from all the sensors for 3rd and 4th August 2021. The black dashed lines denote where the change points (CPs) occurred, and the dashed red lines denote when breakfast (B), lunch (L) and dinner (D) were served to the patients on the ward. Noise from the PM signals was removed using a cubic smoothing spline in R (<https://www.R-project.org/>), with the smoothing parameter set to 0.1. Epochs are in min.




Figure 4. Collated CO₂ signals from all the sensors for 3rd and 4th August 2021. The black dashed lines denote where the change points (CPs) occurred, and the dashed red lines denote when breakfast (B), lunch (L) and dinner (D) were served to the patients on the ward. Epochs are in min.

Indoor CO₂ levels mainly reflect occupancy patterns [51–54], with exhaled CO₂ being positively correlated with respiratory aerosol emissions [55]. However, levels do fluctuate rapidly, likely due to the large volume space and changing shift patterns. The study data would not, therefore, support using CO₂ alone as a marker of safe ventilation.

When the ACU was in operation, PM levels reduced significantly across all sensors, including those distant to the unit, with the effect less pronounced for the PM₄ and PM₁₀ signals, reflecting the lower particle counts in this size range and the fact that larger particles tend to settle out of the air at a faster rate. This confirmed that the ACU cleaned the air as anticipated, but the extent of its impact, as a single machine, was unexpected. The installed ACU had a high velocity laminar discharge, which promoted good air mixing, and this, combined with a high CADR, extended its ‘reach’ and greatly assisted in PM removal throughout the ward. It is hypothesized that this likely extended the air cleaning impact of the unit beyond its immediate environment. Therefore, when installing units, it is important to ensure a similar extended cleaning effect, at least to the mid-point of any adjacent ACUs. Furthermore, it is important to validate the performance of any ACUs that are installed by nebulizing an inert saline solution into the air, and observing the impact of the ACU on the decay process [something undertaken on the study ward prior to the natural experiment, but not reported here (results available on request)]. Validation not only demonstrates the efficacy of ACUs, but also helps to inform their placement so that performance can be optimized.

In addition to filtering out PM, it was observed that the ACU reduced CO₂ levels unexpectedly when switched on. Given that neither HEPA nor UV-C affect CO₂ levels, it is postulated that better air mixing on the ward prevented the gaseous CO₂ from stratifying, thus reducing concentrations at the level of the sensors. Alternatively, the ACU may have increased air velocities

within the ward space to such an extent that additional ‘fresh air’ may have been entrained in from outside. While both explanations appear plausible, it is difficult to explain the magnitude to the reduction in CO₂ levels observed in Figure 4 simply by better mixing alone, especially as the sensors were mounted >1.5 m above floor level. This requires further investigation.

Limitations

This study involved a single ward built before regulations required higher air change rates and the installation of doors to separate bays, something that likely influenced PM movement between the various ward subcompartments. Therefore, the authors cannot be certain that the results are generalizable to other settings, although wards of this age and design are not uncommon in the UK and other countries.

The authors were not able to determine the proportion of measured PM that comprised respiratory aerosols, and while historical ward ventilation data existed, the actual air change rates that occurred during the study were not known because it was a natural experiment. The various sensors on the ward were also not placed at the same height due to operational constraints, which may have influenced the PM counts observed. Furthermore, staff occupancy and movements, and window and door opening were not recorded. Therefore, conclusions concerning the mechanisms by which PM and CO₂ were generated and removed from the ward space remain hypothesis generating rather than confirmed.

Door and window opening can alter the airflow characteristics of ward spaces and the performance of the ACU. For example, closing doors to ward side rooms may isolate these spaces from the ACU, allowing the PM concentration to increase. Additionally, external wind pressure can contribute to the migration of aerosol particles indoors. The authors were not able to evaluate these factors, so further work is required

Table II

Results of statistical test of the hypothesis that the signal levels were higher when the air cleaning unit (ACU) was not in operation on 3rd August 2021 compared with a matched period on 4th August 2021 when it was in operation

Signal	Sensor ID	ACU off mean (SD)	ACU on mean (SD)	Significance P-value	Effect size Cliff's delta	Effect magnitude
PM1	G	3.73 (1.30)	1.03 (0.41)	<0.001	0.99	Large
	F	5.05 (2.35)	1.10 (0.71)	<0.001	0.96	Large
	E	2.83 (0.70)	0.89 (0.40)	<0.001	0.98	Large
	A	2.96 (0.87)	0.35 (0.24)	<0.001	1.00	Large
	B	2.61 (0.57)	0.90 (0.43)	<0.001	0.96	Large
	C	2.60 (0.57)	0.82 (0.38)	<0.001	0.98	Large
	D	2.64 (0.61)	0.82 (0.39)	<0.001	0.98	Large
PM2.5	G	0.39 (0.31)	0.06 (0.03)	<0.001	0.97	Large
	F	0.75 (0.65)	0.09 (0.16)	<0.001	0.92	Large
	E	0.22 (0.13)	0.06 (0.07)	<0.001	0.93	Large
	A	0.20 (0.14)	0.02 (0.01)	<0.001	1.00	Large
	B	0.20 (0.11)	0.06 (0.07)	<0.001	0.90	Large
	C	0.15 (0.08)	0.05 (0.04)	<0.001	0.93	Large
	D	0.17 (0.09)	0.05 (0.04)	<0.001	0.93	Large
PM4	G	0.15 (0.19)	<0.01 (0.01)	<0.001	0.59	Large
	F	0.37 (0.43)	0.022 (0.10)	<0.001	0.63	Large
	E	0.04 (0.07)	<0.01 (0.04)	<0.001	0.33	Small
	A	0.04 (0.09)	<0.01 (<0.01)	<0.001	0.27	Small
	B	0.04 (0.07)	0.010 (0.04)	<0.001	0.32	Small
	C	0.02 (0.05)	<0.01 (0.02)	<0.001	0.22	Small
	D	0.03 (0.06)	<0.01 (0.02)	<0.001	0.34	Medium
PM10	G	0.03 (0.04)	<0.01 (<0.01)	<0.001	0.55	Large
	F	0.07 (0.09)	<0.01 (0.02)	<0.001	0.60	Large
	E	0.01 (0.02)	<0.01 (<0.01)	<0.001	0.26	Small
	A	0.02 (0.04)	<0.01 (<0.01)	<0.001	0.26	Small
	B	0.01 (0.01)	<0.01 (<0.01)	<0.001	0.24	Small
	C	0.01 (0.03)	<0.01 (0.01)	<0.001	0.20	Small
	D	0.02 (0.03)	<0.01 (0.01)	<0.001	0.33	Small
CO ₂	G	815.18 (139.89)	513.28 (109.67)	<0.001	0.90	Large
	F	734.24 (80.02)	479.59 (111.88)	<0.001	0.88	Large
	E	691.24 (72.78)	501.26 (72.28)	<0.001	0.92	Large
	A	713.82 (80.28)	499.45 (78.06)	<0.001	0.91	Large
	B	818.86 (115.04)	520.79 (105.35)	<0.001	0.93	Large
	C	833.17 (121.85)	494.87 (85.35)	<0.001	0.95	Large
	D	748.61 (113.94)	447.10 (102.95)	<0.001	0.93	Large
VP	All sensors	1.37 (0.05)	1.18 (0.06)	<0.001	0.98	Large

PM, particulate matter; PM1, PM fraction <1 µm diameter; PM2.5, PM fraction between 1 and 2.5 µm diameter; PM4, PM fraction between 2.5 and 4 µm diameter; PM10, PM fraction between 4 and 10 µm diameter; CO₂, carbon dioxide; VP, vapour pressure; SD, standard deviation. All results were strongly significant after Bonferroni's correction.

to investigate their impact on ACU performance. Notwithstanding this, given that the study utilized data collected on two consecutive days on the same ward, it is unlikely that door and window opening or staff behaviour were systematically different between the two time periods. Furthermore, local weather conditions throughout the study period were fairly constant, with a light breeze from the south-east occurring on both days. Therefore, although no data on window/door opening exist, this represents a relatively minor limitation which does not change the overall conclusions of the study. In particular, given the nature of microbial bioaerosols in hospitals [11,39–41], it is highly likely that a reduction in these by any mechanism will improve indoor air quality. As such, this work offers important insights into the effect of ACUs on an inpatient ward.

In conclusion, this study builds on previous work showing that ACUs reduce microbial contamination in ward air [39], demonstrating that the application of a combined HEPA/UV-C ACU on an older adult inpatient ward reduced airborne PM levels substantially, most notably in the size range associated with respiratory viruses, such as SARS-CoV-2. Therefore, such devices may be applicable not only to pathogens traditionally considered airborne, such as measles and tuberculosis, but also where aerial dissemination contributes to the transmission of fungal and bacterial infections, such as with *Clostridioides difficile* spores [56].

This study found that airborne particulates associated with human activity migrated considerable distances around the ward, indicating that social distancing measures alone are unlikely to prevent the transmission of respiratory viral infections and possibly other infections that are aerielly

disseminated. Collectively, this suggests that appropriately sized ACUs have the potential to reduce nosocomial infections, especially in inadequately ventilated hospital wards. Further work is needed to investigate this, and inform the placement and commissioning of ACUs to ensure optimum performance.

Author contributions

Conceptualization: MJB, VLK, CBB.

Data curation: DS, CBB.

Software: CBB.

Formal analysis: CBB.

Funding acquisition and project administration: VLK, MJB.

Investigation and validation: DS, MJB.

Methodology and supervision: MJB, VLK, CP, ACM, CBB.

Resources: TG, RT, DS.

Writing – original draft preparation: CBB.

Writing – reviewing and editing: all authors.

Conflict of interest statement

Darren Sloof is the founder, director and shareholder of Air Purity Ltd. Air Purity designed and supplied the air cleaning units and air sensors used in this study. Air Purity Ltd had no role in the study design or analysis of the data. Darren Sloof did collect the data and liaise with other authors over its interpretation. Dr Andrew Conway Morris is a member of the scientific advisory board of Cambridge Infection Diagnostics. Dr Theodore Gouliouris has received materials from Shionogi for conducting a laboratory evaluation. The other authors report no conflicts of interest.

Funding source

This work led to a larger project which is ongoing, the Addenbrooke's Air Disinfection Study (AAirDS). AAirDS is funded by the UK Health Security Agency and was approved by the NHS Health Research Authority and Health and Care Research Wales (IRAS ID 299336) and the Central Bristol Research Ethics Committee (REC reference: 22/SW/0010). This research was supported by NIHR Cambridge Biomedical Research Centre (BRC-1215-20014). The views expressed are those of the authors and not necessarily those of NIHR or the Department of Health and Social Care. VLK was funded by a MRC/NIHR Clinical Academic Research Partnership Grant (MR/T023902/1). Dr Andrew Conway Morris is supported by a Clinician Scientist Fellowship from the Medical Research Council (MR/V006118/1).

Ethical approval

The work presented in this manuscript did not constitute research under the UK Policy Framework for Health and Social Care Research and was not subject to formal ethical review.

Appendix A. Supplementary data

Supplementary data to this article can be found online at <https://doi.org/10.1016/j.jhin.2023.02.006>.

References

- [1] Stadnytskyi V, Bax CE, Bax A, Anfinrud P. The airborne lifetime of small speech droplets and their potential importance in SARS-CoV-2 transmission. *Proc Natl Acad Sci* 2020;117:11875–7.
- [2] Miller SL, Nazaroff WW, Jimenez JL, Boerstra A, Buonanno G, Dancer SJ, et al. Transmission of SARS-CoV-2 by inhalation of respiratory aerosol in the Skagit Valley Chorale superspreading event. *Indoor Air* 2021;31:314–23.
- [3] Zhang R, Li Y, Zhang AL, Wang Y, Molina MJ. Identifying airborne transmission as the dominant route for the spread of COVID-19. *Proc Natl Acad Sci* 2020;117:14857–63.
- [4] Tang JW, Marr LC, Li Y, Dancer SJ. COVID-19 has redefined airborne transmission. *BMJ* 2021;373:n913.
- [5] Wang CC, Prather KA, Sznitman J, Jimenez JL, Lakdawala SS, Tufekci Z, et al. Airborne transmission of respiratory viruses. *Science* 2021;373:eabd9149.
- [6] Greenhalgh T, Jimenez JL, Prather KA, Tufekci Z, Fisman D, Schooley R. Ten scientific reasons in support of airborne transmission of SARS-CoV-2. *Lancet* 2021;397:1603–5.
- [7] Wong S-C, Chan VW-M, AuYeung CH-Y, Chen JH-K, Yip CC-Y, So SY-C, et al. Air dispersal of respiratory viruses other than severe acute respiratory coronavirus virus 2 (SARS-CoV-2) and the implication on hospital infection control. *Infect Control Hosp Epidemiol* 2022. <https://doi.org/10.1017/ice.2022.186>.
- [8] Dick EC, Jennings LC, Mink KA, Wartgow CD, Inborn SL. Aerosol transmission of rhinovirus colds. *J Infect Dis* 1987;156:442–8.
- [9] Xie X, Li Y, Chwang AT, Ho PL, Seto WH. How far droplets can move in indoor environments – revisiting the Wells evaporation-falling curve. *Indoor Air* 2007;17:211–25.
- [10] Liu L, Wei J, Li Y, Ooi A. Evaporation and dispersion of respiratory droplets from coughing. *Indoor Air* 2017;27:179–90.
- [11] Basu S. Computational characterization of inhaled droplet transport to the nasopharynx. *Sci Rep* 2021;11:1–13.
- [12] Burridge HC, Bhagat RK, Stettler MEJ, Kumar P, De Mel I, Demis P, et al. The ventilation of buildings and other mitigating measures for COVID-19: a focus on wintertime. *Proc R Soc A* 2021;477:20200855.
- [13] Mishra B, Mohapatra SC. Nasal ACE 2 receptors' the gateway to COVID 19? *J Community Health Manag* 2020;7:68–9.
- [14] Hamming I, Timens W, Bulthuis MLC, Lely AT, Gij Navis, van Goor H. Tissue distribution of ACE2 protein, the functional receptor for SARS coronavirus. A first step in understanding SARS pathogenesis. *J Pathol* 2004;203:631–7.
- [15] Hamed I, Shaban N, Nassar M, Cayir D, Love S, Curran MD, et al. Paired nasopharyngeal and deep lung testing for severe acute respiratory syndrome coronavirus-2 reveals a viral gradient in critically ill patients: a multicenter study. *Chest* 2021;159:1387–90.
- [16] Asadi S, Wexler AS, Cappa CD, Barreda S, Bouvier NM, Ristenpart WD. Aerosol emission and superemission during human speech increase with voice loudness. *Sci Rep* 2019;9:1–10.
- [17] Gregson FKA, Watson NA, Orton CM, Haddrell AE, McCarthy LP, Finnie TJR, et al. Comparing the respirable aerosol concentrations and particle size distributions generated by singing, speaking and breathing. *Aerosol Sci Technol* 2021;55:681–91.
- [18] Alsved M, Matamis A, Bohlin R, Richter M, Bengtsson PE, Fraenkel CJ, et al. Exhaled respiratory particles during singing and talking. *Aerosol Sci Technol* 2020;54:1245–8.
- [19] Borges V, Isidro J, Macedo F, Neves J, Silva L, Paiva Mr, et al. Nosocomial outbreak of SARS-CoV-2 in a "non-COVID-19" hospital ward: virus genome sequencing as a key tool to understand cryptic transmission. *Viruses* 2021;13:604.
- [20] Abbas M, Robalo Nunes T, Martischang R, Zingg W, Iten A, Pittet D, et al. Nosocomial transmission and outbreaks of coronavirus disease 2019: the need to protect both patients and healthcare workers. *Antimicrob Resist Infect Control* 2021;10:7.
- [21] Illingworth C, Hamilton W, Warne B, Routledge M, Popay A, Fieldman T, et al. Superspreaders drive the largest outbreaks of hospital onset COVID-19 infection. *OSF Preprints* 2021. <https://doi.org/10.31219/osf.io/wmkn3>.
- [22] Meredith LW, Hamilton WL, Warne B, Houldcroft CJ, Hosmillo M, Jahun AS, et al. Rapid implementation of SARS-CoV-2 sequencing to

- investigate cases of health-care associated COVID-19: a prospective genomic surveillance study. *Lancet Infect Dis* 2020;20:1263–71.
- [23] Schwierzeck V, König JC, Kuhn J, Mellmann A, Correa-Martinez CL, Omran H, et al. First reported nosocomial outbreak of severe acute respiratory syndrome coronavirus 2 in a pediatric dialysis unit. *Clin Infect Dis* 2021;72:265–70.
- [24] Piapan L, De Micheli P, Ronchese F, Rui F, Peresson M, Segat L, et al. COVID-19 outbreaks in hospital workers during the first COVID-19 wave. *Occup Med* 2022;72:110–7.
- [25] Abbas M, Nunes TR, Cori A, Cordey S, Laubscher F, Baggio S, et al. Explosive nosocomial outbreak of SARS-CoV-2 in a rehabilitation clinic: the limits of genomics for outbreak reconstruction. *J Hosp Infect* 2021;117:124–34.
- [26] Hetemäki I, Kääriäinen S, Alho P, Mikkola J, Savolainen-Kopra C, Ikonen N, et al. An outbreak caused by the SARS-CoV-2 Delta variant (B. 1.617. 2) in a secondary care hospital in Finland. *Eurosurveillance* May 2021;26:2100636.
- [27] Wang X, Zhou Q, He Y, Liu L, Ma X, Wei X, et al. Nosocomial outbreak of COVID-19 pneumonia in Wuhan, China. *Eur Respir J* 2020;55:2000544.
- [28] Osuafor CN, Davidson C, Mackett AJ, Goujon M, Van Der Poel L, Taylor V, et al. Clinical features, inpatient trajectories and frailty in older inpatients with COVID-19: a retrospective observational study. *Geriatrics* 2021;6:11.
- [29] Lednicky JA, Lauzardo M, Fan ZH, Jutla A, Tilly TB, Gangwar M, et al. Viable SARS-CoV-2 in the air of a hospital room with COVID-19 patients. *Int J Infect Dis* 2020;100:476–82.
- [30] Curtius J, Granzin M, Schrod J. Testing mobile air purifiers in a school classroom: reducing the airborne transmission risk for SARS-CoV-2. *Aerosol Sci Technol* 2021;55:586–99.
- [31] Beggs CB, Avital EJ. Upper-room ultraviolet air disinfection might help to reduce COVID-19 transmission in buildings: a feasibility study. *PeerJ* 2020;8:e10196.
- [32] Barnewall RE, Bischoff WE. Removal of SARS-CoV-2 bioaerosols using ultraviolet air filtration. *Infect Control Hosp Epidemiol* 2021;42:1014–5.
- [33] Di Gilio A, Palmisani J, Pulimeno M, Cerino F, Cacace M, Miani A, et al. CO₂ concentration monitoring inside educational buildings as a strategic tool to reduce the risk of Sars-CoV-2 airborne transmission. *Environ Res* 2021;202:111560.
- [34] Peng Z, Jimenez JL. Exhaled CO₂ as a COVID-19 infection risk proxy for different indoor environments and activities. *Environ Sci Technol Lett* 2021;8:392–7.
- [35] Shao X, Zhang X. Testing for change points in time series. *J Am Stat Assoc* 2010;105:1228–40.
- [36] Picard D. Testing and estimating change-points in time series. *Adv Appl Probabil* 1985;17:841–67.
- [37] Killick R, Eckley I. Changepoint: an R package for changepoint analysis. *J Stat Software* 2014;58:1–19.
- [38] Romano J, Kromrey JD, Coraggio J, Skowronek J, Devine L. Exploring methods for evaluating group differences on the NSSE and other surveys: are the t-test and Cohen's d indices the most appropriate choices? Annual meeting of the Southern Association for Institutional Research; 2006. p. 1–51.
- [39] Conway Morris A, Sharrocks K, Bousfield R, Kermack L, Maes M, Higginson E, et al. The removal of airborne severe acute respiratory syndrome coronavirus 2 (SARS-CoV-2) and other microbial bioaerosols by air filtration on coronavirus disease 2019 (COVID-19) surge units. *Clin Infect Dis* 2022;75:e97–101.
- [40] Coleman KK, Sigler WV. Airborne influenza A virus exposure in an elementary school. *Sci Rep* 2020;10:1–7.
- [41] Santarpia JL, Herrera VL, Rivera DN, Ratnesar-Shumate S, Reid SP, Ackerman DN, et al. The size and culturability of patient-generated SARS-CoV-2 aerosol. *J Expo Sci Environ Epidemiol* 2022;32:706–11.
- [42] Fears AC, Klimstra WB, Duprex P, Hartman A, Weaver SC, Plante KS, et al. Persistence of severe acute respiratory syndrome coronavirus 2 in aerosol suspensions. *Emerg Infect Dis* 2020;26:2168.
- [43] Beggs CB. Is there an airborne component to the transmission of COVID-19? A quantitative analysis study. medRxiv 2020. <https://doi.org/10.1101/2020.05.22.20109991>.
- [44] Vejerano EP, Marr LC. Physico-chemical characteristics of evaporating respiratory fluid droplets. *J R Soc Interface* 2018;15:20170939.
- [45] Mittal R, Ni R, Seo J. The flow physics of COVID-19. *J Fluid Mech* 2020;894:1–14.
- [46] Seminara G, Carli B, Forni G, Fuzzi S, Mazzino A, Rinaldo A. Biological fluid dynamics of airborne COVID-19 infection. *Rend Lincei Sci Fis Nat* 2020;31:505–37.
- [47] Mingotti N, Grogono D, Dello Iorio G, Curran M, Barbour K, Taveira M, et al. The impact of hospital-ward ventilation on airborne-pathogen exposure. *Am J Respir Crit Care Med* 2021;203:766–9.
- [48] Hathway EA, Noakes CJ, Fletcher LA, Sleigh PA, Clifton I, Elliott MW. The role of nursing activities on the bioaerosol production in hospital wards. *Indoor Built Environ* 2013;22:410–21.
- [49] Roberts K, Hathway A, Fletcher LA, Beggs CB, Elliott MW, Sleigh PA. Bioaerosol production on a respiratory ward. *Indoor Built Environ* 2006;15:35–40.
- [50] Rudnick SN, Milton DK. Risk of indoor airborne infection transmission estimated from carbon dioxide concentration. *Indoor Air* 2003;13:237–45.
- [51] Wolf S, Cali D, Krogstie J, Madsen H. Carbon dioxide-based occupancy estimation using stochastic differential equations. *Appl Energy* 2019;236:32–41.
- [52] Ke Y-P, Mumma SA. Using carbon dioxide measurements to determine occupancy for ventilation controls. *ASHRAE Trans* 1997;103:365.
- [53] Hou D, Katal A, Wang LL. Bayesian calibration of using CO₂ sensors to assess ventilation conditions and associated COVID-19 airborne aerosol transmission risk in schools. medRxiv 2021. <https://doi.org/10.1101/2021.01.29.21250791>.
- [54] Jiang C, Masood MK, Soh YC, Li H. Indoor occupancy estimation from carbon dioxide concentration. *Energy Build* 2016;131:132–41.
- [55] Good N, Fedak KM, Goble D, Keisling A, L'Orange C, Morton E, et al. Respiratory aerosol emissions from vocalization: age and sex differences are explained by volume and exhaled CO₂. *Environ Sci Technol Lett* 2021;8:1071–6.
- [56] Roberts K, Smith CF, Snelling AM, Kerr KG, Banfield KR, Sleigh PA, et al. Aerial dissemination of *Clostridium difficile* spores. *BMC Infect Dis* 2008;8:7.